

GENERAL NOTES

- 1. NOTIFY OWNER AND THIS OFFICE OF ANY DISCREPANCIES BETWEEN ARCHITECTURAL AND ELECTRICAL OR MECHANICAL DRAWINGS AND OBTAIN CLARIFICATION BEFORE COMMENCING CONSTRUCTION.
- 2. LOCATIONS OF CEILING PENETRATIONS, SUCH AS AIR DIFFUSERS, GRILLES, LIGHT FIXTURES, ETC. SHALL BE SHOWN ON ARCHITECTURAL REFLECTED CEILING PLANS. WHERE DISCREPANCIES IN LOCATION OCCUR, THE ARCHITECTURAL PLAN SHALL GOVERN. NOTIFY THIS OFFICE & OWNER OF ANY DISCREPANCIES FOR CLARIFICATIONS.
- 3. CEILING HEIGHTS SHALL BE AS SHOWN ON FINISH SCHEDULE.
- 4. EXIT SIGNS:

WHERE REQUIRED: WHEN TWO OR MORE EXITS FROM A STORY ARE REQUIRED, EXIT SIGNS SHALL BE INSTALLED AT STAIR ENCLOSURE DOORS, HORIZONTAL EXITS & OTHER REQUIRED EXITS FROM THE STORY. WHEN TWO OR MORE EXITS ARE REQUIRED FROM A ROOM OR AREA, EXIT SIGNS SHALL BE INSTALLED AT THE REQUIRED EXITS FROM THE ROOM OR AREA AND WHERE OTHERWISE NECESSARY TO CLEARLY INDICATE THE DIRECTION OF EGRESS.

GRAPHICS: THE COLOR & DESIGN OF LETTERS, ARROWS AND OTHER SYMBOLS ON EXIT SIGNS SHALL BE IN HIGH CONTRAST WITH THEIR BACKGROUND. WORDS ON THE SIGN SHALL BE IN BLOCK LETTERS 6 INCHES IN HEIGHT WITH A STROKE OF NOT LESS 3/4 INCHES.

ILLUMINATION: SIGNS SHALL BE INTERNALLY OR EXTERNALLY ILLUMINATED BY TWO ELECTRIC LAMPS OR SHALL BE OF AN APPROVED SELF—LUMINOUS TYPE. WHEN THE LUMINANCE ON THE FACE OF AN EXIT SIGN IS FROM AN EXTERNAL SOURCE, IT SHALL HAVE AN INTENSITY OF NOT LESS THAN 5.0 FOOTCANDLES FROM EITHER LAMP. INTERNALLY ILLUMINATED SIGNS SHALL PROVIDE EQUIVALENT LUMINANCE.

POWER SUPPLY: CURRENT SUPPLY TO ONE OF THE LAMPS FOR EXIT SIGNS SHALL BE PROVIDED BY THE PREMISES WIRING SYSTEM. POWER TO THE OTHER LAMP SHALL BE FROM STORAGE BATTERIES OR AN ON-SITE GENERATOR SET AND THE SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE ELECTRICAL CODE.

SUSPENDED CEILING NOTES

NEW SUSPENDED CEILINGS TO COMPLY WITH ASCE-07 SECTION 13.5.6.

A. A HEAVY DUTY T-BAR SYSTEM SHALL BE USED.

B. THE WIDTH OF THE PERIMETER SUPPORTING CLOSURE ANGLE SHALL BE IN EACH ORTHOGONAL HORIZONTAL DIRECTION, ONE END OF THE CEILING GRID SHALL BE ATTACHED TO THE CLOSURE ANGLE. THE OTHER END IN EACH DIRECTION THALL HAVE A 3/4" CLEARANCE FROM THE WALL AND SHALL REST UPON AND BE FREE TO SLIDE ON CLOSURE ANBLE.

C. EXCEPT WHERE RIGID BRACES ARE USED TO LIMIT LATERAL DEFLECTION, SPRINKLER HEADS AND OTHER PENETRATIONS SHALL HAVE A 2" OVER-SIZED RING, SLEEVE OR ADAPTER THROUGH THE CEILING TILE TO ALLOW FOR FREE MOVEMENT OF AT LEAST 1" IN ALL HORIZONTAL DIRECTIONS.

D. CABLE TRAY AND ELECTRICAL CONDUITS SHALL BE SUPPORTED INDEPENDENTLY OF THE CEILING.

SYMBOLS LEGEND

2' x 4' RECESSED FLUORESCENT LIGHT FIXTURE - SEE ELEC. PLANS

EMERGENCY LIGHTING - SEE ELEC. PLANS

4' SURFACE MTD. FLUORESCENT WRAP AROUND LIGHT FIXTURE - SEE ELEC. PLANS

FLUORESCENT STRIP LIGHT FIXTURE 3 FOOT 2-TUBE - SEE ELEC. PLANS

SURFACE MOUNTED LIGHT FIXTURE - SEE ELEC. DRWGS.

RECESSED "CAN" LIGHT FIXTURE - SEE ELEC.


ELEC. EXHAUST FAN VENTED TO OUTSIDE AIR - SEE MECH. PLANS

SUPPLY AIR GRILLE - SEE MECH. PLANS RETURN AIR GRILLE - SEE MECH. PLAN

INTERNALLY ILLUMINATED EXIT SIGN w/ EMERGENCY BATTERY BACKUP, SEE ELEC. DRWGS.

> BUG EYE EMERGENCY LIGHTING SEE ELEC. PLANS

EERIN EN



H0 ME

DATE: 11/28/11 JOB NO: 11-23 DRAWN: CHECKED: WJH

SCALE: 1/8"=1'-0" SHEET

A-2.2

SHEETS